

Tender No. : 1932/15-C-4-SL(UPS) ,Date:30/09/2019

TENDER DOCUMENT

***E-Tender for supply, installation and commissioning of 2 X 60 KVA online uninterrupted power supply systems (UPS) along with battery system for 60 minutes backup with buy back of existing 2 X 55 KVA UPS alongwith 180 batteries (250 VAH).***

FOR

National Geo-Spatial Data Centre  
Survey of India  
Hathibarkala Estate  
Dehradun (Uttarakhand)  
PIN 248001

Various dates : As mentioned in Sl.4

**1. PREFACE:**

Sealed e-Tenders are invited by The Director, National Geo-Spatial Data Centre, No 6 Block Hathibarkala Estate, Dehradun on behalf of The President of India from reputed and experienced Companies/Firms/Agencies under TWO Bid System i.e. 1) Technical Bid and 2) Financial Bid for **Supply, Installation and Commissioning of 2X60 KVA online UPS along with battery system for 60 minutes back-up time** (Please see Annexure I for specification) at National Geo-Spatial Data Centre, No 6 Block Hathibarkala Estate, Dehradun with **BUY BACK of existing 2X55 KVA UPS NELCO MAKE along with 180 batteries of 250 VAH** (Please see annexure II for specification) on **“as is where is”** basis .

**2. NAME AND ADDRESS OF THE AUTHORITY:**

The Director,  
National Geo-Spatial Data Centre,  
No 6 Block Hathibarkala Estate,  
Dehradun- 248001  
E mail: ngdc.soi@gov.in  
Phone 0135 2747623

**2.1 ADDRESS FOR DOWNLOADING TENDER DOCUMENT:**

<https://www.eprocure.gov.in>  
[www.surveyofindia.gov.in](http://www.surveyofindia.gov.in)

**2.2 CONTACT PERSON(S) FOR ANY QUERIES RELATED TO TENDER:**

Tender related clarification may be obtained from:  
Shri. PANKAJ KUMAR,  
Deputy Superintending Surveyor  
Written queries can be sent by email at: ngdc.soi@gov.in  
Telephone: 0135-2747623

**3. BRIEF DETAILS OF THE E-TENDER:**

|     |   |  |
|-----|---|--|
| i   | Name of the work & location               | <b>Supply, Installation and Commissioning of 2X60 KVA online UPS along with battery system for 60 minutes back-up time</b> (Please see annexure I for specification) at National Geo-Spatial Data Centre, No 6 Block Hathibarkala Estate, Dehradun with <b>BUY BACK of existing 2X55 KVA UPS NELCO Make along with 180 batteries of 250VAH</b> installed at National Geo-Spatial Data Centre, No 6 Block Hathibarkala Estate, Dehradun on <b>“as is where is”</b> basis. |
| ii  | e-Tender No. :                            | 1932/15-C-4-SL(UPS),Date:30/09/2019  |
| iii | Submission of Earnest Money Deposit (EMD) | EMD equal to Rs. 50,000/- in the form of Demand Draft / Banker's Cheque only in favour of "Senior Accounts officer, CP&AO", Dehradun, payable at "Dehradun".   |

SSI units registered with NSIC and MSME can avail the following benefit on submission of relevant certificate:-

- Exemption from payment of earnest money deposit.

### **3.1 SUBMISSION OF THE E- TENDER**

The Tender Document floated for the purpose can be downloaded from [www.eprocure.gov.in](http://www.eprocure.gov.in) and bid can only be submitted through the same website. Bid submitted other than on CPP portal will not be accepted.

**3.2** This Tender is an e-Tender; offers will not be accepted in hard copy.

**3.3** e-Tenders without EMD or EMD exemption certificate are liable to be rejected.

**3.4.** It is also required to submit hardcopies of EMD/EMD Exemption Certificate in original instruments in a sealed envelope super scribed "Supply, Installation And Commissioning of 2X60 KVA Online Uninterrupted Power Supply Systems (UPS) Along With Battery System For 60 Minutes Backup With Buy Back of existing 2X55 KVA UPS NELCO Make along with 180 Batteries 250 VAH" and addressed to "The Director National Geo-Spatial Data Centre, No 6 Block Hathibarkala Estate, Dehradun Uttarakhand 248001" on or before the closing date and time.

**3.5** Bidders who had downloaded the tender from the Central Public Procurement Portal (CPPP) website <https://eprocure.gov.in> shall not tamper/modify the tender form including downloaded price bid template in any manner. In case if the same is found to be tempered/modified in any manner, tender will be completely rejected and EMD would be forfeited and bidder is liable to be banned from doing business with Survey of India.

**3.6** Intending bidders are advised to visit CPPP website <https://eprocure.gov.in> or [surveyofindia.gov.in](http://surveyofindia.gov.in) regularly prior to closing date of submission of tender for any corrigendum/addendum/amendment.

### **4. SCHEDULE FOR INVITATION FOR BIDS:**

- |      |  |                    |
|------|--|--------------------|
| i)   | Date of issue/opening/publish of Tender document   | : 01-10-2019       |
| ii)  | Last date of receipt of Tender                     | : 23 -10-2019      |
| iii) | Date and time of opening of Tender (Technical Bid) | : 25 -10-2019,11AM |
| iv)  | Date and time of opening of Financial Bid          | 28 -10-2019,11AM   |

Bid will be opened at "National Geo-Spatial Data Centre, No 6 Block Hathibarkala Estate, Dehradun Uttarakhand " through e-procurement.

5. **PERIOD FOR VALIDITY OF TENDER DOCUMENT:**  
Six months from the date of opening of the Tender.

6. **TYPE OF BID:**  
Two bid system (Technical & Financial) i.e. Two cover system

7. **PROCEDURE FOR SUBMISSION OF ONLINE BIDS:**

Technical Bid (Cover-1): Bidders are requested to upload the required scanned copies of the documents as per the following:

- ✓ Colour Scanned copies of all information/documents as mentioned in technical Bid document in single PDF file as per "TECHNICAL BID : ELIGIBILITY CONDITIONS"
- ✓ Colour Scanned copy of Demand Draft/ Banker's Cheque of EMD as mentioned in **Para 3(iii)**. Original copy of DD/Bankers Cheque should be submitted to National Geo-Spatial Data Centre, No 6 Block Hathibarkala Estate, Dehradun Uttarakhand 248001 on or before date of opening of technical bid.
- ✓ Financial Bid (BOQ) (Cover-2): Bidders are requested to upload the prescribed **BOQ**.

8. **TECHNICAL BID: ELIGIBILITY CONDITIONS:**

The tendering Company/Firm/Agency shall fulfill the following technical specifications for Technical Bid:-

- (1) Bidder should be a registered company/firm/agency.
- (2) Bidder should have executed and completed at least one work order of supply, installation and commissioning of UPS with Govt./Semi Govt./PSU".
- (3) Bidder should have :-
  - i. The bidder should have minimum 5 years experience with yearly turnover of Rs.4,00,000/- per year in these 5 years. The bidder shall furnish the proof of experience/competence along with the bid, of execution of the similar work. Wherein similar work means Supply, Installation and Commissioning of UPS.
  - ii. The bidder should enclose the photocopy of ITR for last three years.
- (4) Bidder should not have been blacklisted by Central/State Govt./Autonomous body/PSU.
- (5) Bidder should have PAN/TAN, GST registration on his organization name.
- (6) Bidder should have an established office and team of experienced engineer or trained service personnel.
- (7) The bid must be accompanied by an EMD as mentioned in Para 3(iii), in the form of Demand Draft/Banker's Cheque in favour of Senior Accounts officer, CP&AO, Dehradun, payable at Dehradun
- (8) The bid must be accompanied by the Tender acceptance Letter.

## 9. EVALUATION CRITERIA:

- a. Total number of Bids received will be announced to bidders during Bid opening time.
- b. Bidders may remain present during Technical and financial Bid opening.
- c. Technical Bid will be opened first. Only Bidders who qualify Technical Bid will be considered for Financial Bid and only their financial bid will be opened. Financial Bid of the unqualified bidders in Technical Bid will not be opened.
- d. Evaluation committee will evaluate the Technical and Financial Bid and submit their reports to the competent authority.
- e. On the approval of Competent Authority, Lowest One (L-1) bidder name will be declared.

## 10. SCOPE OF WORK

The successful bidder shall supply, install and commission the 2X60 KVA Online Uninterrupted Power Supply Systems (UPS) having suitable isolation transformer along with Battery System for 60 Minutes Battery Backup in good and efficient working condition as per the contract. The warranty period for UPS, isolation transformer, batteries and associated Electrical work carried out by the tenderer for commissioning of UPS will be three years from the date of successful installation. In addition to this, the successful tenderer should provide preventive and corrective maintenance of said UPS, isolation transformer and batteries during warranty period at his own cost and should get verified from authorized official of this office. The successful bidder should also carry out necessary repairs and provide SUITABLE replacement (equivalent or higher configuration) of defective part(s)/ equipments /Electrical work carried out by the tenderer for commissioning of UPS as required during the warranty period at his own cost. The preventive maintenance (PM) is to be carried out once in three months by the successful bidder. The preventive maintenance includes the following:

- Cleaning of UPS and batteries
- Checking battery terminals and Vaseline should be applied periodically to prevent the corrosion on battery leads.
- Checking fitment of internal and external hardware and heating of the system
- Cleaning of PCBs if any and operating power parameters
- Break up call shall be attended immediately
- Checking of tripping devices

## 11. TERMS & CONDITIONS

GENERAL TERMS & CONDITIONS :

- (1) The tenders should be submitted in the prescribed manner as mentioned in Para 7 above.

**(2) Tenders liable to rejection:**

**A.** A tender which does not fulfil all or any of the conditions laid down in this notice or contain conditions not covered and or contemplated by the conditions of contract and or expressly prohibited there in or stipulated additional conditions shall be liable to be rejected and his Earnest money will be forfeited. Tenders shall also be liable for rejection on any of the following grounds.

- a. Conditional tenders.
- b. Tenders not submitted on prescribed Performa.
- c. Tenders without EMD / incomplete tenders / tender without acceptance-letter.
- d. Tenders submitted in hardcopy.
- e. Tenders containing remarks uncalled for.

**B.** Even though the tenderer may meet the above criteria, they are subject to be disqualified if they have:

- i) Made misleading or false representation in the form, statement and attachments submitted in with tender document.
- ii) Record of poor performance such as abandoning the work, not properly completing the contract inordinate delays in completion, litigation history, or financial failures, etc.
- iii) Found to have been black listed in any other works.

(3) **EMD** : The bid must be accompanied by an EMD of Rs.50000/- (Rupees Fifty thousand only) in the form of Demand Draft/Banker's Cheque favouring Senior Accounts officer, CP&AO, Dehradun, payable at Dehradun, EMD of successful bidder shall be released on acceptance of Performance Bank Guarantee. The EMD of unsuccessful bidders shall be refunded within one month of finalization of the tender. No interest shall be paid on the EMD. Bids not accompanied by EMD shall be rejected.

(4) EMD will be liable to be forfeited if the bidder selected for the work fails to sign the formal agreement or to start the work on the date stipulated in the work order.

(5) For any clarification regarding technical details of UPS and the UPS to be buy back you may visit our campus during working days only between 10AM to 5 PM before the last date of tender submission.

(6) Bid shall remain valid for a period of six months from the last date specified for submission.

(7) **Performance Bank Guarantee:-** A performance bank guarantee shall be submitted by the successful bidder for 10% of the total value of bid. It

should be valid for a period of 36 months (Three years) from the contract start date.

- (8) Director National Geospatial Data Centre reserves the right to accept / reject any quotation without assigning any reason.

**SPECIAL TERMS & CONDITIONS:**

- (1) All expenses relating to transportation and installation of materials to site and labour expenses, in whatever form, are to be included in the rate quoted. No separate payment whatsoever for any such item will be provided.
- (2) Work should be completed within 30 days from the date of issuance of work order.
- (3) The supplier may be asked to submit the suitable test certificate to conform the specifications mentioned in annexure I.
- (4) Payment will be made after successful installation and full satisfaction of the Director National Geospatial Data Centre. No Advance payment shall be made by the office.
- (5) The final acceptance of the tender would be entirely vested with Director National Geospatial Data Centre, which reserves the right to accept or reject any tender, at any stage of the tender. The decision of the Director National Geospatial Data Centre in this regard will be final and no disputes in this regard will be entertained.
- (6) Bidders are required to quote firm prices. No cost escalation shall be accepted for payment for the supplies/services.
- (7) The bidder has to submit documentary proof of Sales Tax/PAN/TAN/GST etc.
- (8) Successful bidder shall be issued the purchase order after completion of office procedures as per Government Rules.
- (9) The approved bidder shall not sublet the proposed order in any form whatsoever of supply, installation, commissioning of UPS with Batteries, failing which the purchase order shall be deemed to be cancelled.
- (10) Bid should include the price of the item, all applicable taxes and amount of Buy-Back items in Indian rupees.
- (11) UPS shall be design compliance with IEC standards.
- (12) The comprehensive warranty period for UPS, isolation transformer, batteries and associated Electrical work carried out by the tenderer for commissioning of UPS should be Three years from the date of successful installation. In case any fault or technical problem, the vendor should provide their support within 4 hours for smooth running of the office.
- (13) Inspection of the premises for the purpose of the cost estimation of the UPS with batteries already installed for buy-back purpose can be done

on all working days between 10 AM to 5PM up to one day before the last date and time of submission of bids.

- (14) Successful Bidder shall depute a Qualified Service Engineer or trained service personnel to support and carryout the maintenance works as and when required.
- (15) The preventive maintenance (PM) is to be carried out once in three months by the successful bidder. The preventive maintenance includes the following:
  - Cleaning of UPS and batteries
  - Checking battery terminals and Vaseline should be applied periodically to prevent the corrosion on battery leads.
  - Checking fitment of internal and external hardware and heating of the system
  - Cleaning of PCBs if any and operating power parameters
  - Break up call shall be attended immediately
  - Checking of tripping devices
- (16) **IF** the Equipment after the acceptance thereof be discovered to be defective, (notwithstanding that such defects could have been discovered at the time of inspection) or be found to have failed to fulfill the requirements of the contract or to have developed defects after the erection within a period of 12 months from the date of erection, (whether such erection is done by the Contractor or the Purchaser), **THEN** the Purchaser shall be entitled to give notice to the Contractor setting forth details of such defects or failure and the Contractor shall thereupon (provided such notice is given within a period of 14 months from the date of such erection or acceptance) make good the defective equipment or alter the same to make it comply with the requirements of the contract at his own cost. Provided also that if in the opinion of the Purchaser, the defects are of such a nature that the defects cannot be made good or repaired without impairing the efficiency or workability of the equipment or if in the opinion of the Purchaser the Equipment cannot be repaired or altered to make it comply with the requirements of the Contract, the Contractor, (provided a notice be received from the Purchaser in this regard within a period of 14 months from the date of erection or acceptance thereof), shall remove and replace the same with equipment conforming in all respects to the stipulated particulars, at the Contractor's own cost.
- (17) The successful bidder shall design and furnish all materials and equipment to be fully compatible with electrical, environmental, and space conditions at the site. The successful bidder shall include all equipment to properly interface the AC power source to the intended load and it shall be designed for unattended operation.
- (18) The successful bidder will be responsible for any mishap or accident or untoward incidence during the installation and commissioning of UPS system which may occur due to negligence of the service engineer of the contractor firm. The successful tenderer shall at all times indemnify this office, consequent on this works contract. The successful tenderer shall be liable, in accordance with the Indian Law and Regulations for any accident occurring due to any cause and the successful tenderer shall be responsible for any accident or damage incurred or claims arising there



from during the period of erection, construction and putting into operation the equipments and ancillary equipment under the supervision of the successful tenderer in so far as the latter is responsible. This office shall not be responsible for death, injury or accident to the contractor's employee who may arise out of and in the course of their duties at National Geospatial Data Centre No6 Block Hathibarkala Estate Dehradun

- (19) The successful bidder should provide all the safety equipment's for their employees. In case of any accident due to negligence or unsafe work that requires medical attention, the contractor is wholly responsible and National Geospatial Data Centre will not entertain any claim, compensation, penalty, etc.
- (20) General Financial Rules, 2017 is applicable for all bidders.
- (21) The Bidder shall indemnify this office against all third party claims of infringement of patent, trademarks or industrial design and intellectual property rights arising from the use of equipments and services or any part thereof.
- (22) **Force Majeure:**  
Neither party shall be in breach of any obligation under this contract if it is unable to perform that obligation in whole or part by reason of Force Majeure. If either party seeks to rely on this clause, it shall immediately give notice to the other with full particulars of the matter claimed as a Force Majeure event. The parties so affected shall take all reasonable steps to remedy the failure to perform and to keep the other party informed of the steps being taken to mitigate the effects of Force Majeure. In the event of Force Majeure lasting for more than three months, either party may, following consultation with the other, give a notice of termination.
- (23) **ARBITRATION:** In the event of any dispute or difference(s) between the Director National Geospatial Data Centre and the Bidder(s) arising out in connection with this contract, the same shall be referred to the Surveyor General of India. The decision of the Surveyor General of India will be firm, final and binding on all parties.

#### **LIST OF DOCUMENTS WITH THE TECHNICAL BID**

- i. Application - Technical Bid.
- ii. Attested copy of the registration of agency.
- iii. Attested copy of PAN Card.
- iv. Attested copy of the latest IT return filed by the agency.
- v. Attested copy of the GST certificate.
- vi. Certified documents in support of entries in column 2, 6 and 9 of Technical Bid application Check List.
- vii. Copy of the Tender Acceptance Letter.
- viii. For availing any payment related exemption in tender, a necessary supporting document / certificate shall be submitted.

### TECHNICAL BID CHECK-LIST

|    |  |        |
|----|--|--------|
| 1  | Bidder should be a registered company/firm/agency.<br>(documentary proof may be enclosed)  | Yes/No |
| 2  | <b>Bidder should have :</b><br>Experience of having successfully completed two similar works during last 5 years till 31 March 2019<br>(Attested copy of completion certificate to be furnished)   | Yes/No |
| 3  | Bidder should not have been blacklisted by Central/State Govt./Autonomous body/PSU.(Declaration to be furnished)   | Yes/No |
| 4  | Bidder should have PAN/TAN,GST registration on his organization name<br>(Attested copies need to be furnished )  | Yes/No |
| 5  | Bidder should have last three years Income Tax returns<br>(Attested copies need to be furnished )  | Yes/No |
| 6  | Bidder should have executed and completed at least one work order of supply, installation and commissioning of UPS with Govt./Semi Govt./ PSU".<br>(Attested Copies of work order to be furnished) | Yes/No |
| 7  | Bidders should have an established office and team of experienced engineer or service personnel<br>( Details need to be furnished )  | Yes/No |
| 8  | The bidder should have yearly turnover of Rs.4,00,000/- per year in last 5 years. (Attested documentary proof may be enclosed)   | Yes/No |
| 9  | Earnest Money Deposit (EMD)  | Yes/No |
| 10 | Tender Acceptance Letter   | Yes/No |

## ANNEXURE I

| S. N. | Item   | Quantity           | MAKE          | BACK-UP TIME |
|-------|--|--------------------|---------------|--------------|
| 1.    | 60 KVA online UPS with suitable isolation transformer including required number of Battery system for 60 minutes back-up time on full load.<br>Minimum Battery VAH Required for 60min backup time for each 60KVA UPS System should be <b>96000VAH</b> or more. | 2                  | -             | 60 minutes   |
| 2     | Electrical work necessary for commissioning of UPS   | As per requirement | As compatible | -            |

### Specification of UPS with isolation transformer and Battery system:

- (i) True online double conversion and scalable UPS with suitable isolation transformer
- (ii) The UPS system shall be sized to provide output power of 2 X 60 KVA (120 KVA) during normal operation.
- (iii) The batteries should be Tubular batteries/SMF make of EXIDE, AMRON, ROCKET, QUANTA etc having with ISI mark.
- (iv) Battery system shall have a capacity of 2 X 60 KVA (120 KVA) for at least 60 minutes of backup time under ambient temperature on full load.
- (v) The AC output neutral shall be electrically isolated from the UPS chassis. The UPS chassis shall have an equipment earth terminal.
- (vi) The UPS shall automatically maintain AC power within specified tolerances to the critical load, without interruption (for specified duration as per battery run time), during periods of failure or deterioration of the mains power supply. The UPS shall be equipped with centralized mains **Static Bypass Switch**.

(vii) **UPS Module AC Output:** Three-phase, 4-wire plus ground.

A) **Load Rating:**

100% continuous load rating for any combination of linear and non-linear loads.

Minimum VAH required for battery System=96000VAH

B) **Voltage Range :**

380V/400V/415V (line to line), 220V/230V/240V (line to neutral)

C) **Voltage Stability :** ± 1.5% in steady state.

- D) **Frequency stability** : 50Hz ( $\pm 1\%$ )
- E) **Efficiency** : It is defined as output KW / input KW:
- Not less than 92% at full rated load, nominal input,
  - Not less than 95% at full rated load when supplying the load through the static bypass.
- F) **Phase Tolerance** :  $120^\circ \pm 1^\circ$  for 100% balanced or unbalanced loads.
- G) **Voltage Distortion (at 400V, 100% rated load with crest factor 3:1)** :
- Less than 1% total harmonic distortion (THD) for linear loads
  - Less than 6% total harmonic distortion (THD) for non-linear loads

(viii) **Static Bypass Switch:**

- A) **Bypass Voltage:** 380V/400V/415V (line to line), 220V/230V/240V (line to neutral)
- B) **Bypass Voltage Window:**-20% to +15% on full load
- C) **Overload Capability:**
- Below 110% rated output, long-term operation (no time limitation).
  - From 110 % < load < 125% rated output, more than five minutes.
  - 125% < Load < 150% - More than one minute.
  - $\geq 400\%$  full UPS rated output, 200 milliseconds.

(ix) **Warranty:**

Three(3) years comprehensive on-site warranty on UPS and Three (3) years comprehensive on-site warranty on battery.

(x) **Audible Noise:**

- Less than 55 dB units measured from 1 meter.  
UPS shall be design compliance with IEC standards.

**ANNEXURE II**

**BUYBACK**

(Specifications of existing UPS & Batteries)

(as is where is basis)

| <b>S. NO</b> | <b>Item</b> | <b>Quantity</b> | <b>RATING(A)</b> | <b>MAKE</b> |
|--------------|-------------|-----------------|------------------|-------------|
| 1.           | UPS 55 KVA  | 2 (two)         |                  | NELCO       |
| 2            | Battery     | 180 Nos.        | 2 Volt, 250AH    | TUBULAR     |

## TECHNICAL BID

**FOR SUPPLY, INSTALLATION AND COMMISSIONING OF 2X60 KVA ONLINE UNINTERRUPTED POWER SUPPLY SYSTEMS (UPS) ALONG WITH BATTERY SYSTEM FOR 60 MINUTES BACKUP WITH *BUY BACK OF EXISTING 2X55 KVA UPS NELCO MAKE ALONGWITH 180 (250VAH) BATTERIES.***

1. Name of the Tendering Company/Firm/Agency (Attach certificate of registration)

2. Name of the Proprietor /Director of Company/Firm/Agency

3. Full address of the Registered Office \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Telephone Number : \_\_\_\_\_  
FAX No. : \_\_\_\_\_  
E-Mail Address : \_\_\_\_\_

4. Full address of Branch offices \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Telephone Number : \_\_\_\_\_  
FAX No. : \_\_\_\_\_  
E-Mail Address : \_\_\_\_\_

5. Banker of Company/Firm/Agency \_\_\_\_\_  
(Full Address)

Telephone Number of Banker : \_\_\_\_\_

6. PAN/GIR No. : \_\_\_\_\_  
(Attach attested copy)

7. GST Registration No.(Attach attested copy :

8. Financial turnover of the tendering Company/Firm/Agency for the last 3 financial years. (Attach separate sheet if space provided is insufficient). **Bidder should** have average annual financial turnover during the last 3 years, ending 31st March of the previous financial year, should be at least 30% of the estimated cost.

| Financial Year | Amount in Lakhs | Remarks if any |
|----------------|-----------------|----------------|
| 2016-17        |                 |                |
| 2017-18        |                 |                |

|         |  |  |
|---------|--|--|
| 2018-19 |  |  |
|---------|--|--|

10. Give details of the major similar contracts i.e. supply, installation and commissioning of 2X60KVA online uninterrupted power supply systems (UPS) along with battery system handled by the tendering Company /Firm/ Agency during the last Five years in the following format:**At least one contract shall be with Govt./Semi Govt./ PSU”**

(Experience of having successfully completed two similar works during last 5 years ending last day of month previous to the one in which applications are invited should be either of the following:-

Wherein similar work means Supply, Installation and Commissioning of UPS.

| Sl. No. | Details of client along with address, telephone numbers | Type of UPS | Amount of Contract (in Lakhs) | Duration of Contract |    |
|---------|---|-------------|-------------------------------|----------------------|----|
|         |   |             |                               | From                 | To |
| 1       |   |             |                               |                      |    |
| 2       |   |             |                               |                      |    |
| 3       |   |             |                               |                      |    |

(If the space provided is insufficient, a separate sheet may be attached)

Signature of authorized person

Name: \_\_\_\_\_

Seal: \_\_\_\_\_

Date:

Place:

## DECLARATION

1. I, \_\_\_\_\_ Daughter/Wife of Shri \_\_\_\_\_ signatory of the agency / firm mentioned above is competent to sign this declaration and execute this tender document:
2. I have carefully read and understood all the terms and conditions of the tender and undertake to abide by them:
3. Our company / firm has not been blacklisted by Central / State Govt. / Autonomous body/PSU.
4. The information/documents furnished along with the above application are true authentic to the best of my knowledge and belief. I/We am/are well aware of the fact that furnishing of any false information/fabricated document would lead to rejection of my tender at any stage besides liabilities towards prosecution under appropriate law:

Signature of authorized person

Full Name:

Seal:

Date:

Place:



**TENDER ACCEPTANCE LETTER**  
**(To be given on Company Letter Head)**

*[Department User asks for Tender Acceptance Letter instead of asking Signed Tender Document from the Bidders.]*

**Date:**

**To,**

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**Sub: Acceptance of Terms & Conditions of Tender.**

**Tender Reference**

**Name of Tender / Work: -**

\_\_\_\_\_

Dear Sir,

1. I / We have downloaded / obtained the tender document(s) for the above mentioned Tender/Work' from the web site(s) namely:

\_\_\_\_\_

as per your advertisement, given in the above mentioned website(s).

2. I / We hereby certify that I / we have read the entire terms and conditions of the tender documents from Page No. \_\_\_\_\_ to \_\_\_\_\_ (including all documents like annexure(s), schedule(s), etc., which form part of the contract agreement and I / we shall abide hereby by the terms / conditions / clauses contained therein.

3. The corrigendum(s) issued from time to time by your department/ organization too has also been taken into consideration, while submitting this acceptance letter.

4. I / We hereby unconditionally accept the tender conditions of above mentioned tender document(s) / corrigendum(s) in its totality / entirety.

5. I / We do hereby declare that our Firm has not been blacklisted/ debarred by any Govt. Department/Public sector undertaking.

6. I / We certify that all information furnished by the our Firm is true & correct and in the event that the information is found to be incorrect/untrue or found violated, then your department/ organization shall without giving any notice or reason therefore or summarily reject the bid or terminate the contract, without prejudice to any other rights or remedy including the forfeiture of the full said earnest money deposit absolutely.

Yours Faithfully,